



REPORT OF SOILS FIELD COMPACTION TESTING

CLIENT: Ludlow Construction Co., Inc.
 19 Carmelina's Circle
 Ludlow, MA 01056
 Attn: Mr. Mike Pio

PROJECT: Durham Meadows Waterline
 Durham, CT

DATE: July 22, 2020

REPORT #: 19-75-012-087 Page 1 of 1

General Location: 327 Main Street
Field Rep: Hunter Davis
General Contractor: Ludlow Construction
Earthwork Contractor: Ludlow Construction
Air Temp: 79°F
Weather: Mostly Cloudy
Soil ID#: 3519-608
Soil Type: Light Gray Gravel w/ Silt & Sand (1.5" Gravel)
Proctor Sample Source: Haynes Group

Proctor Value: 138.9 **lbs/ft³** **Optimum Moisture:** 7.8%
Gauge Type: Troxler 3430 **Required Compaction:** 95.0%

TEST NUMBER	DEPTH/ELEV. (in/ft)	MOISTURE (%)	DRY DENSITY (pcf)	COMPACTION (%)
1	8" / 4" BFG	2.6%	132.9	95.7%
LOCATION:	Station #176+02			
LOCATION:				
LOCATION:				
LOCATION:				
LOCATION:				
LOCATION:				
LOCATION:				
LOCATION:				
LOCATION:				

REMARKS: BFG - Below Finish Grade (Base Course for Asphalt)