

## **REPORT OF CONCRETE FIELD & LABORATORY TESTING**

CLIENT: DN Tanks PROJECT: Middletown CT

11 Teal Road 224 Talcott Ridge Drive

Wakefield, MA 01880 Middletown, CT

Attn: Mr. Jake Sreca

**DATE:** August 10, 2020 **REPORT #:** 20-07-161-001 Page 1 of 1

**General Location:** Water Tank, Pipe cover

Date Cast:7/27/2020Field Rep:Stephen SturgesContractor:DN TanksConcrete Supplier:CT Ready MixConcrete Admixtures:Fibermesh, Super P

Air Temp:92 °FWeather:SunnyNominal Size of Aggr:1 1/4"

Date Received by Lab: 7/28/2020

FIELD TEST RESULTS (Sampled in accordance with ASTM C172)

TICKET #	*# CYL	SLUMP TEST (in)	AIR CONTENT (%)	TEMPERATURE (°F)	ELAPSED TIME			
		(ASTM C143)	(ASTM C173)	(ASTM C1064)	Batch	Final	Total (Min)	
1008014	8	8.75"	1.40%	86 °F	8:25 AM	10:00 AM	95	

\*Specimens molded/conditioned in accordance with ASTM C31/ASTM C1231
LABORATORY COMPRESSIVE STRENGTH TESTING (ASTM C39)

Date of	Cylinder ID	Age	Cure	Avg Measured	Cross	PSI	Max. Load	Break Type
Test				Diameter (in)	Sectional (in²)			
07/29/20	1A	2	LAB	6.00''	28.26''	2,320	65,430	3
07/31/20	1B	4	LAB	6.00''	28.26''	2,370	66,920	2
08/03/20	1C	7	LAB	6.00''	28.26''	2,380	67,150	5
08/03/20	1D	7	LAB	6.00''	28.26''	2,440	68,970	5
08/10/20	1E	14	LAB	6.00''	28.26''	2,820	79,610	5
08/24/20	1F	28	LAB					
08/24/20	1G	28	LAB					
	1H		HOLD					



Type 1 Reasonably well-formed cones on both ends, less than 1 in. [25 mm] of



Type 2 Well-formed cone on one end, vertical cracks running through caps, no well-



Type 3
Columnar vertical cracking through both ends, no well-



Type 4
Diagonal fracture with no cracking through ends;



Type 5 Side fractures at top or outtom (occur commonly



Type 6 Similar to Type 5 but end of cylinder is pointed

Specific Sample Location: Water tank, Pipe cover slab

Yards Placed: 4.0 yards<sup>3</sup> Design Strength: 4000 ps

Density: Remarks:

Reviewed By: Darlene Daniels

John Turner Consulting, Inc. considers the information contained in this report to be proprietary. Test results presented herein relate only to those items tested. This document and any information contained herein shall not be disclosed and shall not be duplicated or used in whole or in part for any purpose other than to validate test results without written approval from John Turner Consulting, Inc.