

QUALITY ASSURANCE REPORT (QAR) DAILY LOG OF CONSTRUCTION					REPORT NUMBER 562		Page 1 of 0	
					DATE 02 Jul 2020 - Thursday			
PROJECT Durham Meadows Waterline Remedial Design					CONTRACT NUMBER W912WJ19C0002			
CONTRACTOR Ludlow Construction Co., Inc.					WEATHER Weather Caused No Delay Temperature Min 78 °F Max 88 °F No Precipitation No Wind			
PORTION OF SCHEDULED DAY SUITABLE FOR OPERATIONS					TEMPERATURE		WIND	
STRUCTURAL EXCA- VATION	BORROW EXCA- VATION	EMBANKMENT	CONCRETE	STRUCTURE	MINIMUM	MAXIMUM		
0 %	0 %	0 %	0 %	0 %	78 °F	88 °F	0 MPH	
HAS ANYTHING DEVELOPED ON THE WORK WHICH MIGHT LEAD TO A CHANGE ORDER OR FINDING FO FACT?					24 HOUR PRECIPITATION			
					INCHES		ENDING	
NUMBER OF GOVERNMENT EMPLOYEES SUPERVISORY OFFICE LAYOUT INSPECTION TOTAL LABOR					RIVER STAGE			
					FEET		TIME	
1	0	0	1	2	0	0.0		M
NUMBER OF CONTRACTOR'S EMPLOYEES					NUMBER OF SHIFTS			
					<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3			
0	0	0	0	0730	1530	M	M	M
Attach a list of the following. (a) Major items of equipment either idle or working, and (b) Number and classification of contractor personnel onsite. NOTE: if the contractor's Quality Control Report (QCR) contains the information it need not be repeated.								
QA NARRATIVES								
Work Performed Today: <div style="float: right; text-align: right;"> Unresolved Issue: No Shift: 2 </div> <p>Kurt Mintell</p>								
Results of QA Inspections and Tests, Deficiencies Observed, Actions Taken: <div style="float: right; text-align: right;"> Unresolved Issue: No Shift: 2 </div> <p>Kurt Mintell JTC onsite to take compaction tests at elevation 439.67 in 4 locations. 106% @ 8.7% moisture 98.3% @ 4.8% 99.6% @ 6.6 98.7% @ 5.7%</p>								
Safety: <div style="float: right; text-align: right;"> Unresolved Issue: No Shift: 2 </div> <p>Kurt Mintell Meeting with Rob Peddicord to discuss the Safety needed at the Stream Crossing by the play ground for next week. Will add additional snow fence after hours and ensure the work perimeter is well marked and monitored during the work activities. This is for next week- July 6 - July 10.</p>								
QA REPRESENTATIVE'S SIGNATURE			DATE		RE/PROJECT ENGR'S INITIALS		DATE	